

FILE COPY

TOWN OF ACTON

ENGINEERING DEPARTMENT

DATE: JUNE 2, 1975

TO: CRESCENT PARK REALTY TRUST

SUBJECT: Notice of Inspection - Permit to Construct Within a Public Way / 74-2

LOCATION: Lot 9 - #124 Parker St.

The following work remains to be done:

(1) We have inspected the leaching basins constructed under this permit (Site Plan #2317A) and as per our telephone conversation they will require cleaning prior to release of the Bond. These structures were intended to function as leaching basins, there is no visible evidence in the field that they were built for that purpose.

Please contact us when the work is completed.

Signed

*David Abbott*

Ass't. Town Engineer